



A P P R O V A L S ®

# Certificate of Suitability

## \* Addendum \*

**Certificate No.:** SAA192946

**Date of Issue:** 28 November 2019

**Class Description:** Non-Prescribed

**Product Description:** Surge Protection Device

Additional Models	Trade Name	Rating
V20-1-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280V AC; In L-N: 20kA; Imax L-N: 40kA; Up L-N: ≤1.3kV; T2
V20-1-320	OBO BETTERMANN	Uc (50/60Hz) L-N: 320V AC; In L-N: 20kA; Imax L-N: 40kA; Up L-N: ≤1.4kV; T2
V20-1-385	OBO BETTERMANN	Uc (50/60Hz) L-N: 385V AC; In L-N: 20kA; Imax L-N: 40kA; Up L-N: ≤1.7kV; T2
V20-2+FS-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280V AC; In L-N: 20kA; Imax L-N: 40kA; Up L-N: ≤1.3kV; T2
V20-2+FS-385	OBO BETTERMANN	Uc (50/60Hz) L-N: 385V AC; In L-N: 20kA; Imax L-N: 40kA; Up L-N: ≤1.7kV; T2
V20-2+NPE+FS-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280V AC; In L-N: 20kA; Imax L-N: 40kA; Up L-N: ≤1.3kV; Uc (50/60Hz) N-PE: 255V AC; In N-PE: 40kA; Imax N-PE: 60kA; Up N-PE: ≤1.3kV; T2
V20-2+NPE-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280V AC; In L-N: 20kA; Imax L-N: 40kA; Up L-N: ≤1.3kV; Uc (50/60Hz) N-PE: 255V AC; In N-PE: 40kA; Imax N-PE: 60kA; Up N-PE: ≤1.3kV; T2

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



Issued: 28-11-19 192946/4